

**Water Division  
Status Report  
01/06/16 – 01/12/2016**

**Mark Outs for Street Excavations by PTMUA, PSE&G and JCP&L:**

- 223-231 Eagle Ave
- 83 Sepulga Drive
- 40 Arbutus Street
- Azalea Street
- Arbutus Street
- N. Lakeshore Drive
- 330-334 University
- Eldridge Street

**Water Meters:**

- Completed meter readings in Books 7, 8 & 8A (South Lakeshore)
- Continued meter readings in Books 9 & 10 (North Lakeshore)
- Final readings at 225 Purdue Ave., 392 Lakehurst Rd., 206 Princeton Ave., and 11 Clubhouse Rd.
- Replaced meter at 14 Wasp St.
- Re-read at 109 Columbine

**Water Turn On/Turn Off:**

- Turned off at 18 Beaver Street
- Turned off 103 Barclay – Leak
- Turned off 137 garden - Leak

**Water Wells:**

- Daily routine well checks morning/afternoon
- Added chlorine and polyphosphate to wells as needed
- Replenished chemical supplies at wells
- Water samples
- Assisted Allied Meter with meter calibration at Wells 1, 2, 8A, 11, 12 & 13
- Repaired water leak on booster pump for tank at Well #11
- Checked generator at Well #2 (alarm call). Installed antifreeze in generator/troubleshoot.
- Assisted AC Shultes at Well #11 with booster pump
- Assisted Allied Meter at Well #6

**Miscellaneous:**

- Phone lines out of service at shop
- Inventoried/assembled parts for pipe installation on Duncan
- Picked up supplies from Stevenson's
- Installed water service and main to 118 Duncan
- Replaced service line at 65 Teaberry
- Patched holes on S. Brynwood/Duncan and Teaberry
- Added blend/graded Duncan

- Water quality call at 714 Ford – odor
- Flushed fire hydrant on Forest Avenue
- Assisted S&R with valve locations on Arbutus/Eldridge (BMIA)
- Cut blacktop for service line installation at 59 Teaberry
- Restocked truck #62
- Repaired valve and patched hole at Fort Dix Road and Johnson Court
- Searched for shutoff at 530 Phillips Avenue
- Repaired leak at 30 Johnson Court
- Cut 31 Bank Street out of service
- Located shut off for 530 Phillips – Installed meter and meter box
- Located and dug up shut off for 139 Garden
- Checked leak at County