

**Water Division
Status Report
12/28/16 – 01/03/2017**

Mark Outs for Street Excavations by PTMUA, PSE&G and JCP&L:

- 623 Weymouth (Emergency) • 107 Sepulga Drive •
- • •
- • •
- • •

Water Meters:

- Completed meter readings in Books 5 & 6 (Trenton Road/West Lakeshore)
- Continued meter readings in Books 7, 8, 8A (South Lakeshore)
- Final readings: 130 Trenton Rd., 501 Lakeview Blvd., 16 Trainor Pl., 1826 Hanover Blvd,
- Read Pemberton borough meter

Water Turn Ons/Turn Offs:

Turn off 205 NLSD

Water Wells:

- Daily routine well checks morning/afternoon
- Added chlorine and polyphosphate to wells as needed
- Replenished chemical supplies at wells
- Water samples
- Pump well 11 to waste

Miscellaneous:

- Removed and replaced fire hydrant on Hanover/Magnolia
- Installed new valve box, landscaped area and flushed fire hydrant on Hanover/Magnolia
- Assemble parts for installation
- Check sinkhole on Aster
- Check dry hydrant in PL

- Check markout for Trenton Rd.
- Clean trucks and garage
- Locate water service and turn off 42 Juliustown Rd