

**Water Division
Status Report
10/14/2015 – 10/20/2015**

Mark Outs for Street Excavations by PTMUA, PSE&G and JCP&L:

- 2402 SLSD (Emergency)
- 3 Arneys Mount Road
- 584 Lakehurst (Emergency)
- 6 Howland
- 25 Orange Ave
- 135 Oak Pines Blvd
- 7 Coville Drive

Water Meters:

- Completed meter readings in Books 9 & 10 (North Lakeshore)
- Continued meter readings in Books 11 & 12 (N. Lakeshore/Browns Mills)
- Final readings at 11 Coville Dr., 201 Scammel Dr., 9 Atsuwegi Trail, 43 Clover St., 208 Choctaw Dr.
- Re-read 18 Broadway (Chinese Buffet)
- Replaced meters at 700 S. Brynwood Drive

Water Turn On/Turn Off:

- Turn on at 240 Rutgers Avenue
- Turn off at Imagination Kingdom

Water Wells:

- Daily routine well checks morning/afternoon
- Added chlorine and polyphosphate to wells as needed
- Replenished chemical supplies at wells
- Water samples
- Repaired chlorine line at Well #1
- Unlocked gates at Well #13 for Arctic Heating

Miscellaneous:

- Repaired fire hydrant at 31 Arney's Mount Road. Jack hammered and raised valve box at fire hydrant.
- Repaired/lowered meter box lid at 16 West Lakeshore Drive
- Installed meter box and meter at 12 Scammel Dr., 156 Syringa St., 20 Foxglove St., and 23 Foxglove St., 26 Beaver St., 6 Howland Ave.,
- Referred Verizon Wireless to Pemberton Boro regarding their cell tower on Budd Avenue
- Picked up DPW's steel plate at Emmons/PBM Road
- Located valves on Arney's Mount Road, Fort Dix Road and Weymouth Road
- Maintenance and started generator for tapping machine and prepped for 6" tap on Barclay/S. Brynwood
- Unloaded shipment from Atlantic
- No water call at 20 Lakeview
- Assembled parts for Waverly installation
- Installed water main, 2 valves, 90 degree and tee on Waverly
- Repatched Waverly, landscaped and seeded
- Checked for leak at 102 Crescent Drive