

**Water Division
Status Report
02/01/2017 – 02/07/2017**

Mark Outs for Street Excavations by PTMUA, PSE&G and JCP&L:

- | | | |
|----------------------------|---------------------|---------------------|
| • N. Pemberton (Emergency) | • 123 Elder Avenue | • 2 Arneys Mt. Road |
| • 3 Pine Mill Court | • N. Pemberton Road | • 84 Sepulga |
| • | • | • |
| • | • | • |

Water Meters:

- Completed meter readings in Books 15 & 16 (Browns Mills)
- Continued meter readings in Books 17 & 18 (Pemberton Boro/Country Lakes)
- Read meters in Lakeshore Mobile Village and Pemberton Boro
- Final readings: 45 Poppy St., 22 Trainor, 123 Hunter
- Replaced the water meter at 32 Railroad Street
- Install meters and meter boxes at 606 Cabot and 611 Katherine
- Repair meter at 701 Concord
- Re-reads 14 Rancocas

Water Turn Ons/Turn Offs:

- Water turned on at 32 Railroad Street
- Turn off 129 Newton

Water Wells:

- Daily routine well checks morning/afternoon
- Added chlorine and polyphosphate to wells as needed
- Replenished chemical supplies at wells
- Water Samples
- Fueled the generator at Well #11
- Assisted EMR with generator at Well #11
- Troubleshoot electrical issue at Well #1
- Replaced chlorine injector at Well #1
- Assisted ABS Electric at Well #1
- Purchased fuses at Griffith Electric for chlorinators
- Maintenance at well 11
- Install heater at well 2
- Transport chlorine to well 11 and set up chlorinators

Miscellaneous:

- Located and marked out shut offs for meter box installations in Oak Pines
- Landscape work areas on Cabot and Katherine. Transport excess dirt back to shop.
- Clean up yard at the shop.
- Clean trucks and garage
- Pick up fuses for chlorinators at Pemberton Electric
- Assemble parts for installaton