

**Water Division
Status Report
02/10/16 – 02/16/2016**

Mark Outs for Street Excavations by PTMUA, PSE&G and JCP&L:

- 606 Harding (Emergency)

Water Meters:

- Completed meter readings in Books 17 & 18 (Boro & Country Lakes)
- Continued meter readings in Books 19 & 20 (Lakehurst Road)
- Final readings at 77 Iris St., 331 Woodbine St., 326 Pemberton Blvd., 114 Canna St., and 235 Coville Dr.

Water Wells:

- Daily routine well checks morning/afternoon
- Added chlorine and polyphosphate to wells as needed
- Replenished chemical supplies at wells
- Well maintenance
- Water Samples
- Adjusted Well #13 chlorinator and cleaned injector
- Adjusted the gate at Well #12
- Painted wells
- Prepped wells for DEP inspections
- Assisted AC Schultes at Well #11
- Repaired leaks at Well #12 and Well #13
- Troubleshoot problem at Well #12
- Tested tank at Well #11 booster pump, put back in service

Miscellaneous:

- Performed maintenance on tools
- Assisted DPW with capping sewer pipe on Juliustown Road
- Cleared space to store snow plows
- Attempted to locate shut off at 612 Cabot
- Cleaned tapping tools
- Hooked up and tried to locate Verizon service
- Repaired valve box top at Warren/South Lakeshore Drive
- Removed all plows and salt boxes from trucks
- Water quality calls at 126 Bayberry and 154 Newton street.