

**Water Division
Status Report
02/24/16 – 03/01/2016**

Mark Outs for Street Excavations by PTMUA, PSE&G and JCP&L:

- 236 Rutgers Ave
- 11 Sage St
- 117 Hargrove (Emergency)
- 126 Almond (Emergency)
- 66 Teaberry
- 113 Auburn Ave
- 135 Arneys Mount Road
- 322 Cactus St
- 900 S. Brynwood
- Hunter Blvd
- 248 Amherst Ave

Water Meters:

- Completed meter readings in Books 21 & 22 (Blueberry Manor)
- Continued meter readings in Books 23 & 24 (Blueberry Manor/Lake Valley)
- Final readings at 212 Daniels Ave., 211 Hargrove Ave., and 140 Wilton Way
- Installed meter and meter box at 612 Cabot, 524 Berkley and 28 Phlox St.,
- Replaced water meter at 613 Herbert Rd.,
- Replaced service lines and installed meter and meter box at 66 Teaberry and 900 S. Brynwood
- Read Lakeshore Mobile Village and Pemberton Boro

Water Turn On/Turn Off:

- Turn on at 28 Phlox Street
- Turn on at 102 Scammel Drive

Water Wells:

- Daily routine well checks morning/afternoon
- Added chlorine and polyphosphate to wells as needed
- Replenished chemical supplies at wells
- Well maintenance
- Water Samples
- Chlorinator repair at Well #1
- Attempted to grind stumps at Well #11, stump grinder wouldn't stay running
- Stump grinding at Well #11

Miscellaneous:

- Maintenance/repair stump grinder
- Hauled material from Berkley to garage yard
- Picked up supplies from O'Briens
- Restocked truck #62
- Dug a trench with backhoe for DPW
- Cleaned carburetor on stump grinder
- Patched holes on S. Brynwood, Duncan and Gladiolus