

**Water Division
Status Report
03/09/16 – 03/15/2016**

Mark Outs for Street Excavations by PTMUA, PSE&G and JCP&L:

- Arrahbella Avenue
- 31 Bank Street
- 109 Vance Street

Water Meters:

- Completed meter readings in Books 25 & 26 (Lake Valley)
- Continued meter readings in Books 1 & 2 (Evergreen)
- Final readings at 20 Wildgeese Circle, 335 Sassafras St., and 304 East Lakeshore Drive
- Re-read 237 Princeton Avenue
- Replaced meters at 71 Jefferson, 15 Sepulga and 19 Hydrangea Street

Water Turn On/Turn Off:

- Turned on 19 Hydrangea Street

Water Wells:

- Daily routine well checks morning/afternoon
- Added chlorine and polyphosphate to wells as needed
- Replenished chemical supplies at wells
- Well maintenance
- Water Samples
- Repaired chlorine line at Well #12
- Transported iron out to Wells
- Transported diesel fuel and filled generators at Well #6, 11 and 13
- Replaced chlorine line at Well #2
- Adjusted booster pump and inspected Well #11
- Assisted ABS Electric at Wells
- Static tests at Well #1, Well #4 and Well #111

Miscellaneous:

- Continued installing water main on Barclay Street and landscaped area
- Spread blend and patched holes on Barclay, Waverly, and S. Brynwood
- Raised valve box on Waverly
- Painted fire hydrants
- Re-organized truck #62
- Unloaded shipment of meter boxes from Atlantic Supply
- Greased fittings and performed general maintenance on back hoe
- Repaired leaking water fountain in garage
- Cleaned trucks
- Organized parts and made list
- Located, jack hammered and raised valves on Arrahbella