

**Water Division
Status Report
03/16/16 – 03/22/2016**

Mark Outs for Street Excavations by PTMUA, PSE&G and JCP&L:

- University Avenue
- 236 Amherst Avenue
- 239 PBM Road
- 22 Pointville Road
- 9 Talapoosa Trail
- 336 University Avenue
- 30 Jackson Avenue
- Talapoosa Trail
- Belleview Blvd
- 136 Adams Ave

Water Meters:

- Completed meter readings in Books 1 & 2 (Evergreen)
- Continued meter readings in Books 3 & 4 (Evergreen)
- Final readings at 614 Arlene, 28 Phlox and 240 Rutgers Ave
- Located water meter box at 21 Coreopsis for resident

Water Turn On/Turn Off:

- Turned off 2000 South Lakeshore Drive

Water Wells:

- Daily routine well checks morning/afternoon
- Added chlorine and polyphosphate to wells as needed
- Replenished chemical supplies at wells
- Well maintenance
- Troubleshoot issue with settings at Well #12
- Cleaned up well yard at Well #1

Miscellaneous:

- Painted fire hydrants
- Installed water main on Barclay
- Landscaped area on Barclay
- Patched driveway at 130 Barclay
- Patched road at 154 & 146 Barclay
- Transported 6" pipe to Barclay for installation
- Checked for leak at 58 Dahlia
- Abandoned leaking water service on PBM Road near CVS
- Referred resident to the MUA for sewer problems
- Assembled fire hydrant for installation on Barclay
- Performed maintenance on a trailer and dump truck
- Cleaned trucks and garage
- Updated water maps
- Installed plows on trucks in anticipation of snow fall on 3/20/16
- Replaced valve box at Bobolink/Bellview
- Removed plows from trucks

- Picked up coupling from Stevenson's
- Picked up concrete 4" water blocks from O'Briens
- Loaded stone and parts on truck for fire hydrant installation on Barclay
- Replaced valve box at Bellview/Bobolink
- Distributed water meter installation notice to 17 Wildgeese
- Installed 6" main, valve, tee and fire hydrant on Barclay
- Landscaped area on Barclay
- Disinfected new water main on Barclay
- Loaded fire hydrant and parts for installation on Bobwhite