

**Water Division
Status Report
09/01/16 – 09/06/2016**

Mark Outs for Street Excavations by PTMUA, PSE&G and JCP&L:

- 31 Four Mile (Emergency)
- 304 East Lakeshore Drive
- 214-220 Lakehurst Road
- 304 E. Lakeshore Drive
- 19 Hydrangea Street
- 311 Goldenrod Street
- 137 Juliustown Road
- 419 Salvia St.
- Curtain Avenue
- 23 Sepulga Drive

Water Meters:

- Completed meter readings in Books 23 & 24 (Blueberry Manor/Lake Valley)
- Continued meter readings in Books 25 & 26 (Lake Valley)
- Final readings at 149 Auburn Ave., 156 Medford St., 143 Acorn Ct.,
100 PBM Road-Unit H, 110 Apple Ave., and 114 Oak Pines Blvd.
- Re-connected water meter at 46 Quail Run Road
- Read meters at Lakeshore Mobile Village and Pemberton Boro

Water Turn On/Turn Offs:

- Turned on 130 Trenton Road
- Turned off 130 Trenton Road – Leak
- Turned off 200 College Drive

Water Wells:

- Daily routine well checks morning/afternoon
- Added chlorine and polyphosphate to wells as needed
- Replenished chemical supplies at wells
- Water Samples
- Assisted T-Mobile at the cell tower on Beech Street
- Re-fueled generators
- Assisted EMR Power with generators at Wells

Miscellaneous:

- Replaced service lines at 45 Aster Street and 47 Aster Street
- Replaced service and installed meter and meter box at 69 Aster Street and
2301 North Lakeshore Drive
- Installed meter and meter box at 27 Aster Street
- Landscaped and patched holes on Aster
- One employee received a hearing test at Virtua
- Cut road on Aster for new service line installation

- Repaired copper crimping tool
- Complaint of no water in bathroom sink at 45 Aster. Bathroom sink aerator was clogged.
- Cleaned and re-stocked trucks
- Repaired a sinkhole on Aster Street
- Checked for broken valve lid on Briar Street
- Flushed a fire hydrant on Barclay
- Distributed construction notices on Azalea Street