

**Water Division
Status Report
10/21/2015 – 10/27/2015**

Mark Outs for Street Excavations by PTMUA, PSE&G and JCP&L:

- | | | |
|---------------------------|-------------------------|----------------------|
| • Trenton Road | • 140 Castro Street | • 7 Coville Dr |
| • 320 Yale Rd (Emergency) | • 121-131 Trenton Rd | • 112 Coville Dr |
| • 2003 N. Lakeshore Drive | • 445 Dogwood St | • Kent Street |
| • 107 Pin Oak Drive | • 177 Arneys Mount Road | • 420 Lakehurst Road |
| • | • | • |
| • | • | • |

Water Meters:

- Completed meter readings in Books 11 & 12 (N. Lakeshore/Browns Mills)
- Continued meter readings in Books 13 & 14 (East Lakeshore)
- Re-read meter at 359 Dennis Avenue
- Final readings at 34 Juliustown, 50 Juliustown, 404 White Pine, 386 Lakehurst Rd., 70 Rugby, 313 Goldenrod
- Replaced meters at 51 Peony

Water Turn On/Turn Off:

- Turned 31 Bank Street back on
- Turn off beach building and lifeguard shack
- Ensure 34 Juliustown off
- Turn on 250 Hargrove and 26 Pear

Water Wells:

- Daily routine well checks morning/afternoon
- Added chlorine and polyphosphate to wells as needed
- Replenished chemical supplies at wells
- Repaired leak inside tank at Beech Street
- Removed leaves from wells
- Assisted EMR with generator at Well #11
- Removed sign with graffiti from Well #2
- Met with contractor at Well #2

Miscellaneous:

- Repaired leak at 102 Crescent Drive
- Assembled parts and supplies for 6" tap on Waverly/Barclay
- Repaired water service at 10 Maricopa Trail
- Installed new water main at Waverly Street

- Installed water main and performed 6” tap on Barclay/S. Brynwood
- Unloaded supplies from HD Supply
- Clean/maintenance 6” tapping machine
- Disinfected new main on Waverly
- Landscaped Waverly and Barclay
- Updated maps
- Flushed new main on Barclay and Waverly
- Checked leak at Shell Gas Station. Pumped out meter box.
- Install 125 Barclay and 139 Waverly on new 6” main
- Locate and markout water lines at 50 and 46 Juliustown, 31 Bank
- Paint new fire hydrants on Waverly